

# PRODUCT SPECIFICATIONS



## **EB-002 EXTENSION BRACKET**

Allows a PA-002 tray to be extended to fit beneath a standard 1136 L steel tank.



**BP-002 INSTALL KIT** 

Required for PA-001, PA-003 and PA-009 installation when installing <u>steel</u> tanks with nipple legs. (Not required for fiberglass tanks)



PA-005 L-SHAPED BURNER & FILTER TRAY

DIMENSIONS (L x W x H): 31" x 31" x 2 3/4"

QTY TO TRIGGER ALARM: 1.5 L

CONTAINMENT CAPACITY:



PA-008 RECTANGULAR BURNER & FILTER TRAY

DIMENSIONS (L x W x H): 24" x 13" x 2 3/4"

QTY TO TRIGGER ALARM: 1.0 L

CONTAINMENT CAPACITY: 10.75 L



### PA-001/PA-003 WIDE TRAY

DIMENSIONS (L x W x H): 72" x 27" x 5" (PA-001) 84" x 30" x 5" (PA-003)

QTY TO TRIGGER ALARM: 7.5 L (PA-001) 10.0 L (PA-003)

CONTAINMENT CAPACITY: 189 L (PA-001) 234 L (PA-003)



PA-007 HORIZONTAL TANK TRAY

DIMENSIONS (L x W x H): 49 7/8" x 70" x 3 7/16"

CONTAINMENT CAPACITY: 189 L

PA-002/PA-004

NARROW TRAY

DIMENSIONS (L x W x H): 72" x 14 1/2" x 2 3/4" (PA-002) 72" x 17 1/4" x 2 3/4" (PA-004)

QTY TO TRIGGER ALARM:

2.0 L (Both)

CONTAINMENT CAPACITY:

30 L (PA-002)

49 L (PA-004)



# Alt in the second secon

# A-003 (9V BATTERY)/ A-004 (HARD-WIRED) LEAK DETECTION ALARM

DIMENSIONS (L x W x H): 4 1/2" x 2 3/4" x 1 1/4"

CAN/CSA—C22.2 No. 205 Signal Equipment

ANSI/UL—Std. No. 464 Audible Signal Appliance



PA-009 LARGE RECTANGULAR TRAY

DIMENSIONS (L x W x H): 52" x 34 7/16" x 3"

CONTAINMENT CAPACITY: 72 L



PA-010 SQUARE TRAY

DIMENSIONS (L x W x H): 35 1/4" x 35 1/4" x 3"

CONTAINMENT CAPACITY: 47.9 L

**PRODUCT APPLICATION GUIDE:** 

We have a product for every tank. To view the Product Selection Guide visit our website: **www.oilyeller.com**